

Roof Drain Connection

Uncapped Cleanout

Connected Foundation Drain

Broken House Lateral

4" TO 6" TRANSITION

SEWER LATERAL

Root Intrusion Into Lateral

Storm Cross-Connection

RIGHT-OF-WAY LINE

Faulty Manhole Cover Or Frame

Faulty Lateral Connection

Storm Cross-Connection

STORM SEWER

Cracked Or Broken Sewer Pipe


Deteriorated Manhole

SANITARY SEWER MAIN


KEY

Inflow Source

Infiltration Source



Maintained by the City



Maintained by the Homeowner