

REQUIREMENTS FOR LEAVING A WELL AT DEMOLITION

- The well must be:
 - located outside of the house
 - operational
 - 12 inches above grade
 - a minimum of 3 feet from the building, which includes any overhangs, decks, driveways, etc
 - 10 feet from any gas line or electric service
 - 50 feet from any untested sewer or 20 feet from a tested sewer line
- There must be a backflow preventer.
- There is no variance from these requirements if City water is available.
- A survey will be required to locate the well and to verify all the required clearances.



This document is available in alternate formats upon a 72-hour request. Please call 763-593-8006 (TTY: 763-593 3968) to make a request. Examples of alternate formats may include large print, electronic, Braille, audiocassette, etc.

