



## Requirements For Leaving A Well At Demolition

7800 Golden Valley Road, Golden Valley, MN 55427-4588  
Phone: (763) 593-8090 Fax: (763) 593-3997 TTY: (763) 593-3968

1. The well must be located outside of the house.
2. The well must be operational.
3. The well must be 12 inches above grade.
4. The well must be a minimum of 3 feet from the building, which includes any overhangs, decks, driveways, etc.
5. The well must be 10 feet from any gas line or electric service.
6. The well must be 50 feet from any untested sewer or 20 feet from a tested sewer line.
7. There must be a backflow preventer.
8. There is no variance from these requirements if city water is available.
9. A survey will be required to locate the well and to verify all the required clearances.

Handouts/Bldg/Demo/Wells.08



This document is available in alternate formats upon a 72-hour request. Please call 763-593-8006 (TTY: 763-593-3968) to make a request. Examples of alternate formats may include large print, electronic, Braille, audiocassette, etc.

