



NOTE:
 MINIMUM 2" PER FOOT UNDER 8' OF
 COVER – 2" THICK HIGH DENSITY
 POLYSTYRENE INSULATION (MINIMUM
 TOTAL R VALUE OF 20) LAYERS WITH
 JOINTS STAGGERED AND EXTENDING A
 MINIMUM OF 2' EACH WAY FROM
 WATERMAIN C/L OR AS DIRECTED BY
 THE ENGINEER.

APPROVED JANUARY 1, 2018

CITY ENGINEER REG 23110

**WATERMAIN
 INSULATION**

City of
Golden Valley

GV-WM-050